



ADDENDUM 2 BID OPPORTUNITY NO. 102-2005

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF SLUICE GATES

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: April 7, 2005
BY: Larry Smith, C.E.T.
TELEPHONE NO. (204) 284-0580

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 11 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: Form G2 (R1): Irrevocable Standby Letter of Credit and Undertaking (Bid Security) with Form G2(R2): Irrevocable Standby Letter of Credit and Undertaking (Bid Security).

Replace: Form B: Prices with Form B(R1): Prices.

Replace: Form F: Work Schedule with Form F(R1): Work Schedule.

PART B – BIDDING PROCEDURES

Revise: B2.1 The Submission Deadline is 4:00 p.m. Winnipeg time, April 12, 2005.

Revise: B15.4 With reference to the Evaluated Bid Price Table: Replace the table shown in B15.4 with the following table:

Tag No.s	Target Delivery Date (A)	Bidder's Delivery Date – Form F(R1) – Schedule (B)	No. of Days Difference (if negative, enter "0") (B) – (A)
T-SG-003, T-SG-004, T-SG-008 wall thimbles (3)	August 22, 2005		(1)
T-SG- 002, T-SG-005, SG-006, T-SG-007 wall thimbles (3)	October 7, 2005		(2)
Total days difference (1) + (2)			(3)

Total Bid Price (from Form B)(4)
Total Days (3) above x \$3500 =(5)
EVALUATED BID PRICE (4) + (5) =

PART D – SUPPLEMENTAL CONDITIONS

- Delete D9.1(a)(i).
- Revise D9.1(a)(ii) Delivery of wall thimbles for T-SG-003, T-SG-004, and T-SG-008
- Revise D9.1(a)(iii) Delivery of wall thimbles for T-SG-002, T-SG-005, T-SG-006, and T-SG-007
- Delete D12.1(a).
- Revise D12.1(b) Delivery of wall thimbles for T-SG-003, T-SG-004, and T-SG-008 – three thousand, five hundred dollars (\$3,500);
- Revise D12.1(c) Delivery of wall thimbles for T-SG-002, T-SG-005, T-SG-006, and T-SG-007 – three thousand, five hundred dollars (\$3,500);

PART E – SPECIFICATIONS

- Revise: E6 With reference to Sluice Gate Schedule – Thimble Invert to Base of Pedestal (Top of Concrete), Nominal Size and Wall Thimble:

Delete all references to T-SG-001, T-SG-009, and T-SG-010.

- Revise: E6 With reference to Sluice Gate Schedule – Unseating Head:

Replace the table specified in Addendum 1 with the following table:

Gate No.	Unseating Head (meters)
T-SG-002	6.0
T-SG-003	6.0
T-SG-004	6.0
T-SG-005	6.0
T-SG-006	15.0
T-SG-007	15.0
T-SG-008	15.0

- Delete: E7.1 Replace with the following: “Sluice gates and related equipment shall be delivered adjacent to the Deacon Booster Pumping Station located at Section 23, Township 10, Range 4 EPM. The Installation Contractor shall be responsible for offloading and taking delivery of the equipment. The Contractor shall provide a detailed delivery schedule for gates and thimbles within fifteen (15) calendar days after notification of acceptance.

- Revise: E8.5.1 Replace “For one 1830 millimetre and three 2743 millimetre sluice gates.” with “For one 2743 millimetre sluice gate.”

Clarification to E8.5.1(b): The temporary flange will be supplied and installed by the City under a separate Contract.