

ADDENDUM 4 BID OPPORTUNITY 571-2005

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF DEACON BOOSTER PUMPS

ISSUED: December 12, 2005 BY: Bill Richert, P. Eng. TELEPHONE NO. (204) 986-6053

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E - SPECIFICATIONS

Section 11300

3.3 TESTING

Revise: 3.3.3 to read: The Installation Contractor will provide temporary connections, flow monitoring, pressure

monitoring, ammeters, and temporary tankage required for the performance tests.

Section 11320A

1.4 Pump Dimensions:

Revise Clarification from 571-2005 Addendum 2 to read:

With respect to clauses 1.4.1 and 1.4.2, the existing suction and discharge piping is 900 mm and 600 mm respectively. Pump connection to the existing piping shall be via flanges of similar size if available. If required, the Contractor shall supply detailed fabrication drawings of reducers / increasers for the Installation Contractor to supply and install. The overall flange to flange dimension shall fit within the allotted space shown on the drawings.

DRAWINGS

Replace: 571-2005_Drawing_WX-M001-RA with 571-2005_Addendum_4-Drawing_WX-M001-RB