



## 641-2005 ADDENDUM 1

### ASSINIBOINE PARK ZOO EAST GATE ENTRANCE AND EXIT RENOVATIONS – 700 ASSINIBOINE DRIVE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: December 2, 2005  
BY: Lou Chubenko  
TELEPHONE NO. (204) 986-7278

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050506

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Add: E12.1.2 (d)

E12.1.2 (d) Perforated Transom Infill Panelling – Clear anodized aluminum panels, 3/16 inch thick, ½ inch holes punched at 1 inch on center. Anodizing shall be a good surface on both sides of the panel.