



850-2013 ADDENDUM 2

ELECTRICAL DISTRIBUTION UPGRADE – PAN AM POOL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 12, 2013
BY: Greg Kucel
TELEPHONE NO. (204) 986-3429

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The submission deadline is 4:00 p.m. Winnipeg time, December 17, 2013.

PART E – SPECIFICATIONS

Revise: Section 26 24 13 – Switchboards - Clause 2.6.2 to read:

Breakers 40A and larger to be connected and programmed for zone selective interlocking.

Breakers under 40A shall have LSIG trip units

Add: Section 26 05 73 - Coordination, Short Circuit, and Arc Flash Study