



# 339-2014 ADDENDUM 1

APPARATUS BAY ADDITION – FIRE STATION #6 – 603 REDWOOD AVE

## **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: May 27, 2015  
BY: Evan Wiebe  
TELEPHONE NO. (204) 986-2570

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150105

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

## **PART E – SPECIFICATIONS**

- Delete Item 1.3.1 from Spec section 07 11 13 Bituminous Dampproofing
- Delete Item 1.4.1 from Spec section 07 11 13 Bituminous Dampproofing
- Delete Item 1.5.3.2 from Spec section 07 11 13 Bituminous Dampproofing
- Delete Item 3.4.1 from Spec section 07 27 00 Vapour and Air Barriers
- Revise Spec section 07 52 11 Modified Bituminous Roofing Item 1.6.1 to read
  - .1 For the Work of this Section 07 52 11 – Modified Bituminous roofing. Material warranty is 10 years non-prorated.
- Delete Item 4.2 Related Work from Spec section 09 91 10 Painting
- Add E3 Concrete Column Mix Design
  - 35 MPa compressive strength at 28 days
  - Type 10 cement
  - Water/cement ratio 0.5
  - Max. aggregate 20mm
  - 5%-8% entrained air
- Add Soils Investigation Report, attached.