

703-2018 ADDENDUM 1

ST JOHN'S PARK PATHWAY LIGHTING

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 30, 2018
BY: Steven Repa
TELEPHONE NO. 204 – 451-2723

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: Ar20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION


Replace: Form B: Prices with Form B (R1): Prices - Addendum 1. The following is a summary of changes incorporated in the replacement Bid Opportunity Submission:

Form B(R1): Add Item No. 9 – Supply and Install Decorative Pole Base

PART E – SPECIFICATIONS

Revise: E9.3.4 (b) to read: The light pole shall come with a cast aluminum decorative base that shall be similar to the aesthetic of Figure E9.3.4 b) i) design should include scalloping and a removable access panel. Decorative base shall be 0.3 to 0.6 m in height and is to be powder coated to match colour of pole and luminaire.

Add: E9.3.4 (b) i)



Add: E9.6.1 (g)

The supply and installation of decorative bases will be measured on a per unit basis for, "Supply and Install Decorative Pole Base" on Form:B Prices;

Add: E9.6.2 (g)

The supply and installation of the decorative pole bases shall be paid for at the contract unit price for "Supply and Install Decorative Pole Base" price which work shall include the installation of the decorative base onto the pole. Price shall be payment in full for supply of all materials and performing all operations herein described and for all other items incidental to the work included in this Specification.