



419-2022 ADDENDUM 1

ROOF REPLACEMENTS – TECUMSEH SHOPS – 195 & 215 TECUMSEH

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 19, 2022
BY: David Firth City of Winnipeg
TELEPHONE NO. 204 451-4098

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E2.3 to read: DRYWALL SHEETING

(a) This shall be 5/8" DensDeck Prime as manufactured by Georgia Pacific or CGC Securock or approved equal in accordance with section B7 of the tender.

DRAWINGS

Replace: 419-2022 _Drawing_R-1_195_Tecumseh with 419-2022 _Addendum_1_Drawing_R-2_195_Tecumseh