

1. GENERAL

1.1 Shop Drawings and Product Data

- .1 Submit shop drawings and product data in accordance with Section 16010 - Electrical General Requirements.

1.2 Operation and Maintenance Data

- .1 Provide operation and maintenance data for isolating switches for incorporation into manual specified in Section 16010 - Electrical General Requirements.
- .2 Technical data to cover operating mechanism of group operated switches.

1.3 Maintenance Materials

- .1 Provide maintenance materials in accordance with Division 01 - Maintenance Materials, Special Tools and Spare Parts.

2. PRODUCTS

2.1 Isolating Switch

- .1 Indoor, three pole, vertical breaks, group operated, cubicle mounted, continuous rating 1200 A at 5 kV, manual operating mechanism, key interlocked.

2.2 Equipment Identification

- .1 Provide equipment identification in accordance with Section 16010 – Electrical General requirements.
- .2 Equipment labels: Name Plate size 7.

3. EXECUTION

3.1 Installation

- .1 As indicated on Drawings and specified herein.

END OF SECTION