NOTES:

FED FROM:

MOUNTING:

MAIN BREAKER:

100A

MAINS:

225A

FEEDER:

#250

MCM

CONSULTANT DRAWING NO. 41-09-0265-366-00 EEUER Winnipeg POWER DISTRIBUTION ENCLOSURE AND SCHEMATIC **©** SAND/SALT STORAGE FACILITY PUBLIC WORKS YARD 1539 WAVERLEY STREET THE

ISSUED FOR CONSTRUCTION
ISSUED FOR REVIEW

04Apr23 04Apr02 DATE

HOR. SCALE:
VERTICAL:
Y/M/D: C

AS SHOWN

RELEASED FOR CONSTRUCTION DATE SON 122/09

DESIGNED BY

SCK

DRAWN BY

SCK

APPROVED BY POR

• Construction • Management Services CHECKED Konvito SINEER'S SEAL

PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION

SHEET

유

90

PEV REV

CITY DRAWING NUMBER N/A

CITY

0

WINNIPEG

WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES

UMA Engineering Ltd.
No. 256 Expiry: April 30, 2004

Certificate of Authorization
UMA Engine

BID OPORTUNITY No. 187-2004

S.W. crn. Waverley St. & Chevrier Blvd. Tblt. in N. conc. found. #1539 Waveley 1.0m W. & O.9m below brick of N. E. corner of Building

SURFACE DISTRIBUTION CIRCUIT BREAKER INSTALLED LOCATION: PΥ NORTH SIFT CONTRACT. SIDE SAND/SALT CONNECTION STORAGE UNDER BLDG. SEPARATE CONTRACT


VOLTAGE: SPACE **EAST** WEST H/0 M/0 120/208 DOOR DOOR OPERATOR OPERATOR PHASE: S 20 3P 20 3P WIRE: BREAKER .c.: 10 ₹

1 OUTDOOR LTG. N.E. CORNER BLDG.
3 OUTDOOR LTG. S.E. CORNER YARD
5 OUTDOOR LTG. S.W. CORNER YARD
7 OUTDOOR LTG. N.W. CORNER YARD
9 OUTDOOR LTG. N.W. CORNER BLDG.
1 OUTDOOR LTG. N.W. CORNER BLDG.
3 BLDG. LTG. — NORTH
5 BLDG. LTG. — CENTRE
6 BLDG. LTG. — HPS WALL PACKS
1 BLDG. RECEPT
1 BLDG. RECEPT.
5 CALCIUM TANK RECEPT. DESCRIPTION DISTRIBUTION LOAD TRIP N AMPS ABC 20 20 20 20 20 20 20 20 20 PANEL TRIP AMPS 20 3P LOAD Þ, CALCIUM (
SPARE
SPARE
SPARE
SPACE
SPACE CALCIUM SUPPLY PUMP DISTRIB. ENCLOS. RECEPT OCCUPANCY SENSORS CALCIUM FILL PUMP CONTROL PANEL
CHLORIDE ACTUATORS DESCRIPTION P-2



FRONT ELEVATION





PANEL 'A' 120/208V, 3PH
4W, 225A MAINS C/W 100A
3P MAIN CIRCUIT BREAKER
SUITABLE FOR SERVICE
ENTRANCE USE

PANEL A

BUILDING LIGHTING CONTROL
PANEL - WATT STOPPER
LP8-S-8-115
8 RELAY LIGHTING CONTROL
PANEL SUITABLE FOR
120/277 VAC LIGHTING
CIRCUITS

RAIN HOOD

PHOTOCELL

1400W × 2000H × 610D —— EEMAC 4 ENCLOSURE FOR ELECTRICAL DISTRIBUTION AND CONTROL SYSTEM

DOUBLE DOORS C/W 1 CAPTIVE -DOOR 3-POINT LATCH LOCKABLE HANDLE

- ENCLOSURE LOUVRES C/W INTERNAL BUG SCREEN, TOP AND BOTTOM, BOTH SIDES

CONCRETE FOUNDATION REFER TO DWG. 05

25x6x450 COPPER GROUND BAR

<u>e</u>

SPACE FOR FUTURE LIQUID DE-ICER STORAGE TANK PUMP CONTROL PANEL. MIN. 600 × 600

UTILITY DUPLEX RECEPT.