



ADDENDUM NO. 1 BID OPPORTUNITY NO. 452-2004

**CONSTRUCTION OF NEW FOUNDATION AND TRAILER RELOCATION
341 CADBORO ROAD –WINNIPEG POLICE SERVICE FACILITY**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 2, 2004
BY: Coleen Groening /I
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20040901

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART E – SPECIFICATIONS

Revise E7.2.1a) to read:

E7.2.1 a) All sawn lumber shall be No. **2** Common Construction Grade S-P-F- pressure treated wood. All plywood shall be ½" pressure treated wood.

Revise E9.1.1a) to read:

E9.1.1 a) All material, labour and plant necessary for the supply and installation of **steel** railings as shown on the drawings.