



ADDENDUM NO. 1 BID OPPORTUNITY NO. 579-2004

2004 WASTEWATER PUMPING STATIONS INLET CONTROL VALVE INSTALLATIONS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 15, 2004
BY: Douglas Berg
TELEPHONE NO. (204) 986-4452

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20040901

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid Submission non-responsive.

PART E – SPECIFICATIONS

Revise: Drawing 05523 - where shown 375 diameter Gate Valve and 375 diameter Flange Adapter or Wall Thimble, replace with 350 diameter Gate Valve and 350 diameter Flange Adapter or Wall Thimble, respectively.

Revise: Drawing 05526 - where shown 375 diameter Gate Valve and 375 diameter Flange Adapter or Wall Thimble, replace with 350 diameter Gate Valve and 350 diameter Flange Adapter or Wall Thimble, respectively.

Revise: Drawing 05530 - where shown 375 diameter Gate Valve and 375 diameter Flange Adapter or Wall Thimble, replace with 350 diameter Gate Valve and 350 diameter Flange Adapter or Wall Thimble, respectively.