



## **ADDENDUM No. 1 BID OPPORTUNITY NO. 111-2005**

**SUPPLY & INSTALLATION OF CONCRETE PILE BASES, LIGHT STANDARDS, FIXTURES AND RELATED WORKS AT R.A. STEEN C.C./ LAURA SECORD SCHOOL – 960 WOLSELEY AVENUE**

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: April 19, 2005  
BY: Lou Chubenko  
TELEPHONE NO. (204) 986-7278

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D2.2 (b) to read: Supply and install (1) additional key switch on the **exterior electrical panel** so that the East rink **lighting** can be operated independent of the West rink **lighting**. Provide 4 pole 30A rated contactors as required in NEMA 4 enclosure.

### **PART E – SPECIFICATIONS**

Revise: E3.3 (e) to read: Supply and install (1) additional key switch on the **exterior electrical panel** so that the East rink **lighting** can be operated independent of the West rink lighting. Provide 4 Pole 30A rated contactors as required in NEMA 4 enclosure

### **DRAWINGS**

Replace: Drawing 111-2005\_Drawing\_L2-R0.pdf with Drawing 111-2005\_Addendum\_1-Drawing\_L2\_R1.pdf