



## **ADDENDUM 1 BID OPPORTUNITY NO. 189-2005**

Legion Memorial Park and Marjorie Park Playground Redevelopments

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: May 10,2005  
BY: Stefan Fediuk  
TELEPHONE NO. (204) 986-5597

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

Revise: E2.2.3 Play Components

(a) Style 3: (see Drawing L.14-J)

(iv) one (1) Stainless Steel Slide, with north or east face orientation

Revise: E2.3.2 Materials

(a) Topbeam

(i) All topbeams shall be fabricated from 3 1/2" O.D. 7 gauge, RS40 galvanized steel pipe. All fabrication cuts, drill holes and weld joints shall be sprayed with a corrosion resistant coating.

(b) Legs

(i) All legs shall be fabricated from 2 3/8" O.D. 10 gauge, RS40 galvanized steel pipe. All fabrication cuts, drill holes and weld joints shall be sprayed with a corrosion resistant coating. The bottom end of the posts is to be sealed with a moisture barrier.