



ADDENDUM 2 BID OPPORTUNITY NO. 427-2005

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF GRANULAR ACTIVATED CARBON FILTRATION SYSTEM

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 1, 2005
BY: Bill Richert, P. Eng.
TELEPHONE NO. (204) 986-8392

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Section 11201

Revise: 1.3.1.4 to read: Submit a detailed description of the proposed delivery and installation procedures as part of the submission made pursuant to D16.1(a)(ii). Installation procedures shall be based on all media transfer equipment, hoses, etc. provided by the Contractor as required by GC.5.02, and with Plant service water flow rate of less than 378 litres per minute at 343 kPa pressure. Any booster or drainage pumping required for installation of the media shall be provided by the Contractor. Location of sanitary sump for up to 378 litres per minute drainage is at the intersection of gridlines B13 and BD on Drawing WF-M0002 issued in Addendum No.1. Backwash water shall be directed to the plant residuals treatment system.

Revise: 2.2.1.2.6 to read: Maximum total ash content of 12 percent by weight.

Delete: 2.2.1.2.9

Revise: 2.2.1.2.10 to read: Apparent Density of 0.46-0.60 grams per cubic centimetre

Delete: 2.2.1.2.12

Revise: 3.2.1.8.1 to read: Place the GAC media in three lifts of 700 millimetres up to total depth of 2100 millimetres and level by backwashing after placement of each lift.

Section 11203

Revise: 2.1.1 to read: U.S. Filter, Ames IA; Multicrete II Plenum type underdrain.