



# ADDENDUM 4 BID OPPORTUNITY NO. 515-2005

## WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF RAW WATER PUMPS

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: October 21, 2005  
BY: Bill Richert, P. Eng.  
TELEPHONE NO. (204) 986-6053

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

### PART A – BID SUBMISSION

Replace: 515-2005\_Addendum\_3-Bid\_Submission with 515-2005\_Addendum\_4-Bid\_Submission  
(Form A(R1) has been replaced by Form A(R2) and Form G2(R2) has been replaced by Form G2(R3))

### PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, November 2, 2005.

### PART E – SPECIFICATIONS

#### **Section 11320**

Revise: 2.4.3 to read: The discharge column shall be flanged connection. Maximum section length shall be 3000 mm.

Revise: 2.5.3 to read: Lineshaft materials shall conform to ASTM A108, Grade 1045 carbon steel. The shaft size, machining tolerances, and straightness shall comply with AWWA E101-77, Section 4.3. The lineshaft surface shall be precision-turned, ground, and polished.

Revise: 2.5.4 to read: The lineshaft shall be provided in the maximum section lengths of 3000 mm. Sections shall be interchangeable. Lineshaft couplings shall be of identical material to the line shaft and shall ensure the tight butting of adjacent sections. Couplings shall be split ring or keyed as required by the application.

#### **Section 11320a**

Revise: 1.3.12 to read: Minimum pump bowl efficiency for all flow conditions (%): 75.

Delete: 1.3.13