



ADDENDUM 1 BID OPPORTUNITY NO. 561-2005

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF WATER TREATMENT PLANT SLUICE GATES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: October 31, 2005
BY: Larry Smith, C.E.T.
TELEPHONE NO. (204) 986-7635

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

E6. SLUICE GATE SCHEDULE

E6.4 Gate Schedule For Area F (Filtration Area)

Change the table **Wall Thickness** to read:

Gate No.	Wall Thickness (millimeters)
SLG-F001A	300 millimetre at the base and 300 millimetre at the top
SLG-F053A	400 millimetre at the base and 400 millimetre at the top
SLG-F054A	400 millimetre at the base and 400 millimetre at the top
SLG-F055A	600 millimetre at the base and 600 millimetre at the top