



ADDENDUM 7 BID OPPORTUNITY 583-2005

WINNIPEG WATER TREATMENT PROGRAM – WATER TREATMENT PLANT FOUNDATIONS AND CONCRETE STRUCTURES

ISSUED: March 28, 2006
BY: Bill Richert, P. Eng.
TELEPHONE NO. (204) 986-6053

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Section 03300

- Delete: 1.3.1
- Delete: 1.3.2.1.1
- Delete: 1.3.2.1.2
- Add: 1.3.2.1.5 Structural concrete exposed to earth or groundwater shall meet the requirements of CSA A23.1-04 exposure class S1.
- Add: 1.3.2.1.6 Structural concrete not exposed to earth or groundwater shall meet the requirements of CSA A23.1-04 exposure class C1.
- Add: 1.3.2.1.7 All wall concrete shall utilize a super plasticizer (S.P.) S.P. shall be added on Site with slump requirement of 80 mm +/- 30 mm prior to addition of S.P.
- Add: 3.16.6 Construction joints: All horizontal construction joints shall receive an initial coating of 40 MPa ready-mix supplied grout mixture.
- Clarification: All references in the Drawings and Specifications to Type A and Type B concrete shall be superceded by the criteria specified above.