

602-2005 ADDENDUM No 1

SUPPLY AND DELIVERY OF BIOREACTOR AERATION EQUIPMENT FOR THE WEST END WATER POLLUTION CONTROL CENTRE BNR UPGRADE PROJECT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 09 2005
BY: Eric Hutchison PEng
TELEPHONE NO. (204) 477-5381

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read:

The submission deadline is 4:00 pm Winnipeg time, December 20, 2005

PART D – SUPPLEMENTAL CONDITIONS

Delete Form H1: Performance Bond and Delete Form H2: Irrevocable Standby Letter of Credit (Performance Security)

PART E – SPECIFICATIONS

Section 01010 Clause 1.2.2

DELETE the phrases "control philosophy", "loop drawings", and "I/O exchange tables"

Section 01300 Clause 3.2

REVISE TO READ

Three (3) advance copies of the manuals shall be submitted prior to equipment delivery to Site for review and comments. A minimum of eight weeks after review, six (6) copies of the final manuals shall be supplied. Each copy shall be clearly titled to show all of the information required by the Specifications as well as operational information including: the item of Work concerned, the City's Contract number, the name and address of the Contractor, the issue date, operational information on equipment, cleaning and lubrication schedules, filters, overhaul and adjustment schedules.

Section 11531 Clause 1.1.2

CLARIFICATION

The factory test shall simulate the design conditions (including but not limited to water depth, diffuser density and arrangement, and airflow). Testing procedure and arrangements shall be submitted to the Contract Administrator for review prior to beginning the test.