

## SEE NOTE#1 (TYP) DUPLEX SPECIAL PURPOSE DUPLEX SPECIAL PURPOSE EXIST. BEAM ABOVE QUADRUPLEX SEE NOTE#2 (TYP) NOTE#5 (TYP) SEE NOTE#5 (TYP) NOTE#6 (TYP) SEE NOTE#6 (TYP) TICKET BOOTH NO. 1 TICKET BOOTH NO. 2 NEW WOOD BEAM ABOVE QUADRUPLEX - SEE NOTE#1 (TYP) ELECTRICAL PLAN LAYOUT SCALE 1:50



ELEVATION-TICKET BOOTH No.2 SCALE 1:50



ELEVATION-TICKET BOOTH No.1 SCALE 1:50

## **LIGHTING NOTES FOR DRAWING E-1**

NOTE #1: 6 existing pot lights to be maintained in same positions with minor repairs and trim touchups/ trim replacement as necessary. Fixture condition to be evaluated on site. New A19 120V lamps to be installed (wattage to be determined). 2 existing pot lights in new Ticket

Booth#1 space to be disconnected and removed.

NOTE #2: Supply and install four (4) directional 8" 120V incandescent surface downlights (2 at each ticket booth, mounted over the exterior of the ticket window). Lamp to be PAR38 flood, wattage to be determined. Use Pace Cilindro EDTC Series fixtures or approved

equivalent. Finish to be dark bronze.

NOTE #3: Two (2) existing exterior wall-mounted fixtures to be repaired and re-used for up-lighting in the tower (existing wire covers to be removed and discarded). Fixture condition to be evaluated on site. In the event that existing fixtures are not repairable, supply and install Lithonia WFL2 series fixtures (or approved equivalent) in the same wattage as existing fixtures. Finish to be dark bronze. New lamps to be installed, lamps to be metal halide where possible (lamp type and wattage to be determined on site).

> Supply and install two (2) surface-mount fixtures for exterior path lighting. Use Lithonia WFL2 series fixtures (or approved equivalent) in same voltage as fixtures for tower up-

lighting. Lamp to be metal halide, wattage to be determined.

Supply and install the following interior surface mount fixtures (or approved equivalent): NOTE #5:

Fixture – 2 x Lithonia LB-2-17-120-GEB Lamp – 2 x F17T8 Booth1:

Fixture – 2 x Lithonia LB-2-32-120-GEB Booth2: Lamp - 2 x F32T8

Supply and install the following track lighting with directional heads (or approved

equivalent):

NOTE #4:

Track - 1 x Lithonia ArchiTrak AKT4WH Booth1: Head - 2 x Lithonia ArchiTrak AKTSCP20WH

Lamp - 2 x 45PAR16/H/NFL 120V

Booth2: Track - 1 x Lithonia ArchiTrak AKT6WH

Head – 3 x Lithonia ArchiTrak AKTSCP20WH

Lamp - 3 x 45PAR16/H/NFL 120V



