



## **ADDENDUM NO. 6 BID OPPORTUNITY NO. 674-2005**

**CONSTRUCTION OF AN ALTERNATE EMERGENCY COMMUNICATION  
CENTRE – 700 ASSINIBOINE PARK DRIVE, WINNIPEG, MB**

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: April 3, 2006  
BY: Kerry Feeney  
TELEPHONE NO. (204) 942-0981

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20040901

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.**

---

### **PART E – SPECIFICATIONS**

**Add: Section 05500 Metal Fabrications (attached)**

**Revise: Section 06200 Finish Carpentry**

Add: 2.6.7 as follows:  
"Keyboard Tray: K & V Model No. 5700 Keyboard Tray."

Add: 2.6.8 as follows:  
"Closet Rod: 15/16" diameter chrome rod, K & V Model No. 770-5 complete with K & V 764 end cap."

#### **Section 07552 Modified Bitumen Roofing**

Add: 2.5.2 as follows:  
"Sloped Insulation: Type 2 expanded polystyrene, tapered to suit requirements indicated on drawings."

#### **Section 08700 Door Hardware**

Add: 2.1.3 as follows:  
"Approved Equal: Horton 4100LE Door Operator within Sets 1, 2, 6 and 7."

#### **Section 09306 Floor Tile**

Add: 2.1.2 as follows:  
"Tile is available from: Buckwold Western  
70 Plymouth Street  
Winnipeg, MB R2X 2V7  
Phone (204) 633-7572"

**Revise: Section 09650 Resilient Flooring**

Add: 2.4.3 follows:  
"Extent of stair covering in existing Stairwell 100-4 includes basement level with landing up to Door 100-4-E up to roof access including landing at Door 100-4-F without interruption."

Add: 2.4.4 as follows:  
"Extent of stair covering in existing Stairwell 100-2 includes basement level with landing up to Door 100-2-D and up to Second Level including landing at Door 100-2-C without interruption."

**Section 12495 Roller Shades**

Revise: 2.1.2 as follows:  
"Similar products by MechoShade and Sun Project may also be used."

**Section 16622 Power Generation Diesel**

Revise: 2.2.2 as follows:  
"RATED – 3 Phase, 347/600, 4-wire, 60 Hz, Continuous Duty, 125 deg. C Temperature Rise."

**PART F – DRAWINGS**

Add: Drawing RA-1

Add: Drawing RA-2

Add: Drawing RA-3

Add: Drawing RA-4

Add: Drawing RA-5

Add: Drawing RA-6

Add: Drawing RA-7

Add: Drawing RA-8

Add: Drawing RA-9

Add: Drawing RA-10

Add: Drawing RA-11

Add: Drawing RA-12

Add: Drawing RA-13

Revise: Drawing E-14, Item: CSTE

The CSTE shall be c/w 1-600 amp, 3P breaker 100% rated for the feeder to the ATS.  
The CSTE shall be c/w 1-600 amp, 3P breaker 100% rated for the feeder to 6MD-A.

Breakers shall be LSI type to match the breaker that they are feeding.

Revise: Drawing E-14, Item: ATS

Delete the service entrance rated breaker shown in the ATS.