

## DRAWING NOTES

- 1 LIFTING EYE.
- 2 PIPE STAND SUPPORT. 3 HEAT EXCHANGER STAND TO BE SUPPLIED AND INSTALLED BY CONTRACTOR.
- 75mmx50mm REDUCER FROM PIPE TO PUMP DISCHARGE AND SUPPLY.
- 5 FOOT VALVE.
- 6 EFFLUENT RETURN PIPE END TO BE BELOW WEIR EL. 230.62.
- 7 COORDINATE WITH GENERAL CONTRACTOR FOR PROPER PIPE PENETRATION THROUGH CONCRETE FLOOR. ENSURE PIPE SLEEVES ARE SIZED FOR PIPES TO BE REMOVED.
- 8 300x300 ACCESS OPENINGS IN MEZZANINE FLOOR FOR PIPE LIFTING.
- 9 6000 S/A DUCT FROM U-420-AHU-1.
- 10 DROP HYDRONIC PIPING DOWN IN FRONT OF VENTILATION DUCT TO AVOID INTERFERENCES.
- 11) 1000 CGS/CGR TO/FROM HEAT EXCHANGERS IN UV ROOM. SIZES AS SHOWN.
- (12) 1500 STORM FROM MECHANICAL ROOM.
- (13) WALL MOUNTED FIRE EXTINGUISHER.
- 14 LOCATION AND INSTALLATION OF U-420-AHU-1 SHALL BE COORDINATED WITH STRUCTURAL AND GENERAL CONTRACTOR.
- (15) TYPICAL FLEX CONNECTION.

## **GENERAL NOTES**

- 1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
- 2. PROVIDE 100mm HOUSEKEEPING PAD UNDER ALL FLOOR MOUNTED AIR HANDLING EQUIPMENT, PUMPS AND AIR COMPRESSORS.

ELEV. CHECKED DRAWN BY APPROVED **Certificate of Authorization** HOR. SCALE: AS NOTED RELEASED FOR CONSTRUCTION BY: Earth Tech Canada Inc. VERTICAL SCALE: AS NOTED T. KJARTANSON No. 730 Expiry: April 30, 2005 0 ISSUED FOR TENDER 05/02/18 JEH

NO. REVISIONS

DATE BY DATE

2004/12/08

DATE 2005-02-18

ENGINEER'S SEAL

ORIGINAL SIGNED BY

P.V. LAITINEN

FEB. 18/05

CONSULTANT DRAWING NO.

66303D-CM6.02

## THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT

NEWPCC - SECONDARY EFFLUENT	CITY FILE NUMBER
UV DISINFECTION FACILITY	SHEET 9 OF 18
MECHANICAL SECTIONS	CITY DRAWING NUMBER