



ADDENDUM 10 BID OPPORTUNITY 742-2005

WINNIPEG WATER TREATMENT PROGRAM – SUPPLY AND INSTALLATION OF WATER TREATMENT PLANT PROCESS MECHANICAL AND ELECTRICAL

ISSUED: June 22, 2006
BY: Bill Richert, P. Eng.
TELEPHONE NO. (204) 986-6053

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Section 15100-00

Delete: 3.3.4

Section 15200-000

Revise: 3.19.4 to read All HP, GOX, OZO and OZG piping that is supplied as passivated by the Contractor or by the City and that is subsequently welded during the performance of the Work shall be re-pickled and re-passivated (internally) in accordance with 3.19.1.

Section 16431

Revise: 2.1.4.1 to read Provide a multi-port communication card that will support communications via three independent ports:

Add: 2.1.4.1.1 One (1) RS-232C/RS-485, and one (1) RS-485

Add: 2.1.4.1.1.1 Protocols: ION, Modbus RTU

Add: 2.1.4.1.1.2 Baud rate: RS-232, 300 bps to 115,200 bps.

Add: 2.1.4.1.1.3 Baud rate: RS-485, 300 bps to 57,600 bps.

Add: 2.1.4.1.2 Ethernet port:

Add: 2.1.4.1.2.1 Protocols: ION, Modbus TCP.

Add: 2.1.4.1.2.2 10Base-FL,

Add: 2.1.4.1.2.3 Simultaneous communications using ION and Modbus TCP protocols

Delete: 2.1.4.2

Delete: 2.1.4.3

Delete: 2.1.4.4