FILTER TANK NO. 5 FILTER TANK NO. 7 FILTER TANK NO. 6 - STAIRWELL NO. 6 WB-M9452 (BY OTHERS) FIR-150 245.000 STANDPIPE (BY OTHERS) - FOR THIS CONTRACT, END 75mm DRAIN PIPE AND 13mm TRAP PRIMER PIPE 300mm BELOW SLAB, TYP - FOR THIS CONTRACT, END 100mm CLEANOUT PIPE 300mm BELOW SLAB, TYP FILTER TANK GALLERY WB-M9452 FD−1−TP -(SWD-250) UP AND DOWN \_\_\_13mm TRAP SEAL DRA-100 (BY OTHERS) PRIMER TO TRAP, TYP OF 3 (BY OTHERS) ✓INV EL 243.610 SWD-250 TPD (BY OTHERS) BD (BY OTHERS) 9 WB-M9452 FOR THIS CONTRACT, END 13mm SEAL PRIMER PIPE 300mm ABOVE FINISHED FLOOR, TYP —INV EL 243.615 ≻EXP JQINT WB-M9452 ~INV EL 243.730 THIRD FLOOR PLAN 1:100 WO WA KEY PLAN SCALE 1:100 B.M. ELEV. ENGINEER'S SEAL CH2MHILL THE CITY OF WINNIPEG EarthTech
A Tyco International Ltd. Company Winnipeg WATER AND WASTE DEPARTMENT ENGINEERING DIVISION Frederickson Cooper ORIGINAL SIGNED BY D.K. CUDDINGTON CHECKED BY WATER TREATMENT PLANT DESIGNED CITY FILE NUMBER **Certificate of Authorization** JZ/SW FILTRATION 2006/02/06 DRAWN BY APPROVED BY CH2M HILL Canada Ltd. SHEET OF FOUNDATIONS AND CONCRETE STRUCTURES No. 1441 Expiry: April 30, 2006 RELEASED FOR CONSTRUCTION BY: CITY DRAWING NUMBER 1:100 SCALE: PLUMBING CONSULTANT DRAWING NO. R. SOROKOWSKI PIPE EMBEDS 00 ISSUED FOR TENDER 2006/02/03 SW 1-060**1F**-A-H9134-001-00D FILTRATION AREA 2 THIRD FLOOR PLAN WF-H9134 NO. REVISIONS DATE BY DATE DATE 2006/02/08 2005/08/02