

CP-P31	DAF Basins 1-4 Control Panel		Jumper or Internal Cable	Conductor #	Cable	Cable Information	
Comments	Switch 1		RJ-45 To PLC	01	_____	_____	
	RJ-45 To PLC	02	_____	_____	_____		
		03	_____	RJ-45	C-CP-P31-C01	4-Pair #24 AWG - Cat 5E TO CP-P31A	
		04	_____	RJ-45	C-LCP-P11A-C01	4-Pair #24 AWG - Cat 5E TO LCP-P11A	
		05	_____	RJ-45	C-LCP-P34-C01	4-Pair #24 AWG - Cat 5E TO LCP-P34	
		06	_____	RJ-45	C-LCP-P33-C01	4-Pair #24 AWG - Cat 5E TO LCP-P33	
		07	_____	RJ-45	C-LCP-P32-C01	4-Pair #24 AWG - Cat 5E TO LCP-P32	
		08	_____	RJ-45	C-LCP-P31-C01	4-Pair #24 AWG - Cat 5E TO LCP-P31	
		09	_____	RJ-45 To Local HMI	_____	_____	
	Spare	10	_____	_____	_____	_____	
	Spare	11	_____	_____	_____	_____	
	Spare	12	_____	_____	_____	_____	
	Spare	13	_____	_____	_____	_____	
	Spare	14	_____	_____	_____	_____	
	Spare	15	_____	_____	_____	_____	
	Spare	16	_____	_____	_____	_____	

NOTES: 1. Panel Supplied by the City.	B.M. ELEV.			 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
				DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER
				DRAWN BY	SWT		APPROVED BY	AHL	SHEET 25 OF 63	
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:		CITY DRAWING NUMBER	
			0	ISSUED FOR TENDER	06/03/29	SWT	CONSULTANT DRAWING NO.	1-0601H-J-A0525-001-00B		
			NO.	REVISIONS	DATE	BY	WH-A0525			

