

Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information
	PP1			
Plant Control Network Receive	Switch 1: 07-Rx	01	01	C-CP-P31A-C01 12-Strand 62.5/125 um Multi-mode TO CP-H32A
Plant Control Network Transmit	Switch 1: 07-Tx	02	02	
Remote I/O Network Receive	PP1: 15	03	03	
Remote I/O Network Transmit	PP1: 16	04	04	
Plant Monitoring Network Receive	PP1: 17	05	05	
Plant Monitoring Network Transmit	PP1: 18	06	06	
		07	07	
		08	08	
		09	09	
		10	10	
		11	11	
		12	12	
Plant Control Network Transmit	Switch 1: 08-Tx	13	01	C-CP-H31A-C01 12-Strand 62.5/125 um Multi-mode TO CP-H31A
Plant Control Network Receive	Switch 1: 08-Rx	14	02	
Remote I/O Network Transmit	PP1: 03	15	03	
Remote I/O Network Receive	PP1: 04	16	04	
Plant Monitoring Network Transmit	PP1: 05	17	05	
Plant Monitoring Network Receive	PP1: 06	18	06	
		19	07	
		20	08	
		21	09	
		22	10	
		23	11	
		24	12	

NOTES: <div style="border: 1px solid black; padding: 5px; text-align: center;">  Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006. </div>	B.M. ELEV.			 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
				DESIGNED BY	SWT	CHECKED BY	SWT	ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29	
				DRAWN BY	SWT	APPROVED BY	AHL		
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:		
		0	ISSUED FOR TENDER	06/03/29	SWT				CONSULTANT DRAWING NO. WH-A0526
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29	
							WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL		CITY FILE NUMBER
							AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS		SHEET 26 OF 63 CITY DRAWING NUMBER 1-0601H-J-A0526-001-00B

Monday, April 03, 2006