



ADDENDUM 1 BID OPPORTUNITY NO. 89-2005

SUPPLY AND DELIVERY OF VERTICAL AXIAL FLOW PROPELLER PUMPS WITH VARIABLE FREQUENCY DRIVES COMPLETE WITH FABRICATED DRAFT TUBE AND INTERCONNECTING PIPEWORK FOR THE NORTH END WATER POLLUTION CONTROL CENTRE DISINFECTION PROJECT.

ISSUED: April 12, 2005
BY: T Roziere
TELEPHONE NO. (204) 986-4623

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20050301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Section 11313 Clause 2.20 Revise 2.20.1 to read as follows:

2.20 Spare Parts

- .1 Provide the following spare parts:
 - .1 Two (2) casing gaskets and O-rings for motor/pump and for the cable duct.
 - .2 Two (2) sets of mechanical seal assemblies.
 - .3 Two (2) O-rings for discharge column sealing.
 - .4 Two (2) casing wear rings.
 - .5 Two (2) sets of bearings, motor side.
 - .6 Two (2) sets of bearings, pump side.
 - .7 One (1) propeller.

Section 11313 Clause 2.20 Delete 2.20.2

PUMP STATION MODEL TEST REPORT

The City commissioned a Pump Station Model Test, the report is being made available with this Addendum.