



193-2006 ADDENDUM 1

PLAYGROUND REDEVELOPMENT AT MILDRED PARK

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 31, 2006
BY: Debbie Shkolny
TELEPHONE NO. (204) 986-2249

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E5.5.1(c) to read: All concrete footings for playstructures shall be a minimum of **3'** depth, or in accordance with Manufacturer's specifications, whichever is greater.