ELECTRICAL SYMBOL LEGEND LIGHTING POWER FIRE ALARM FLUORESCENT LUMINAIRE — SURFACE OR SUSPENDED DUPLEX RECEPTACLE MANUAL PULL STATION CIRCUIT BREAKER · · · FLUORESCENT LUMINAIRE - RECESSED SINGLE RECEPTACLE BELL C/W VISUAL ALARM LIGHT DRAW OUT CIRCUIT BREAKER CIRCUIT BREAKER C/W CURRENT FLUORESCENT EMERGENCY LUMINAIRE ISOLATED GROUND RECEPTACLE WALL MOUNTED HORN LIMITERS -SURFACE OR SUSPENDED 52 800A WALL MOUNTED HORN/STROBE POWER CIRCUIT BREAKER C/W Ø CEILING POT OR HID LUMINAIRE — SURFACE OR SUSPENDED SPLIT-FEED RECEPTACLE FRAME SIZE INDICATION STAB TYPE DISCONNECT E WALL MOUNTED BELL WALL SCONCE OR HID LUMINAIRE GROUND FAULT RECEPTACLE **⇔**¤ <del>-</del> 어마 LIGHTNING ARRESTER WALL MOUNTED BELL/STROBE STANCHION MOUNTED HID LUMINAIRE SPECIAL 120V RECEPTACLE X SURGE ARRESTER CEILING MOUNTED EXIT LIGHT SPECIAL 208V 1¢ RECEPTACLE CEILING MOUNTED HORN - ARROWS AS REQUIRED  $H\!\boxtimes$ THERMAL OVERLOAD DEVICE  $\sim$ WALL MOUNTED EXIT LIGHT SPECIAL 208V 3Ø RECEPTACLE SMOKE DETECTOR ARROWS AS REQUIRED +CONTACT RATE OF RISE THERMAL DETECTOR BATTERY PACK C/W HEADS AS INDICATED SPECIAL 347V RECEPTACLE 1/-CONTACT WALL MOUNTED EMERGENCY REMOTE HEADS SPECIAL 600V RECEPTACLE FIXED TEMPERATURE THERMAL DETECTOR = 125kVAR **(20)** CAPACITOR C/W KVAR RATING PHOTO ELECTRIC CELL SPECIAL RECEPTACLE DUCT MOUNTED SMOKE DETECTOR ²3 E TC POTENTIAL TRANSFORMER C/W END OF LINE RESISTOR TIME CLOCK MOTOR CONNECTION VOLTAGE AND QUANTITY 400/5 CURRENT TRANSFORMER C/W SPRINKLER FLOW SWITCH NIGHT LIGHT DIRECT CONNECTION - CONNECTION TO RATIO AND QUANTITY EQUIPMENT SUPPLED UNDER OTHER DIVISIONS. (101) ZERO SEQUENCE CURRENT zsct — LUMINAIRE TYPE SPRINKLER PRESSURE SWITCH TRANSFORMER DISCONNECT SWITCH DM DIGITAL METERING SINGLE POLE SWITCH SPRINKLER VALVE MONITOR FUSED DISCONNECT SWITCH TRANSIENT VOLTAGE SURGE SUPRESSOR CONTROL MODULE WALL SWITCH: 3 - THREE WAY LV- LOW VOLTAGE MAGNETIC MOTOR STARTER 4 - FOUR WAY M - MOTOR RATED VFD VARIABLE FREQUENCY DRIVE D — DIMMER PL- PILOT LIGHT SOLENOID VALVE EX- EXPLOSION PROOF WP- WEATHER PROOF COMBINATION DISCONNECT/MAGNETIC MOTOR STARTER METERING DEVICE FIRE PHONE V – VOLTAGE kW - KILOWATTS MANUAL MOTOR STARTER C/W PILOT LIGHT A — AMPERAGE kVAR – KILOVARS FIRE ALARM SPEAKER PF - POWER FACTOR PANEL BOARD - SURFACE MOUNTED ELECTRIC MOTOR MISC. PANEL BOARD - FLUSH MOUNTED COMMUNICATION HARMONIC FILTER KW RATED WEATHER PROOF GROUND FAULT DISTRIBUTION TRANSFORMER  $\frown$ VOICE OUTLET A.F.F. ABOVE FINISHED FLOOR DELTA DATA OUTLET START-STOP PUSHBUTTON WYE VOICE/DATA OUTLET OVERHEAD GARAGE DOOR OPENER WYE OR STAR WITH SOLID GROUNDED NEUTRAL GROUND SECURITY STARTER - FVNR CARD READER FULL VOLTAGE NON-REVERSING DOOR POSITION SWITCH MOTION DETECTOR STARTER - SOFT START 美 LINE SYMBOLS CABLE NUMBER STARTER - 2 SPEED, 1 WINDING CONDUCTOR UNDERGROUND CONDUCTOR OVERHEAD CONDUCTOR B.M. ELEV. ENGINEER'S SEAL THE CITY OF WINNIPEG **Earth Tech** WATER AND WASTE DEPARTMENT Winnipeg ENGINEERING DIVISION ORIGINAL SIGNED BY A Tyco International Ltd. Company Certificate of Authorization P. STRYK DESIGNED CHECKED CITY FILE NUMBER WEWPCC Earth Tech Canada Inc. BIOLOGICAL NUTRIENT REMOVAL UPGRADE APPROVED 2006/04/26 DRAWN CONTRACT 3 No. 730 Expiry: April 30, 2006 RELEASED FOR CONSTRUCTION BY: HOR. SCALE: NTS CITY DRAWING NUMBER ELECTRICAL VERTICAL SCALE: CONSULTANT DRAWING NO. AREA L - GENERAL AND SITEWORKS J. VEILLEUX 00 ISSUED FOR TENDER 06/04/26 ERC LE1.01 SYMBOL LEGEND REVISIONS DATE | BY | DATE 2005/11/22 DATE 2006/04/26