



31-2006 ADDENDUM 2

SUPPLY AND DELIVERY OF DECANTERS FOR THE NORTH END WATER POLLUTION CONTROL CENTRE CENTRATE NITROGEN REMOVAL FACILITY

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: March 20, 2006
BY: Eric Hutchison P.Eng.
TELEPHONE NO. (204) 477-5381

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

1. Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, March 31, 2006.

PART E – SPECIFICATIONS

1. Clarification of Section 01010 clause 1.1.2.2: Since the Contractor is not responsible for the process design of the SBR system, the operating and control philosophy is limited to the decanters and related equipment (e.g. VFDs, limit switches where applicable, and other associated components).
2. Revise: Section 01010 clause 1.1.2.3 to read: Provision of necessary performance specifications and equipment material required to ensure optimal function of the decanter units. This will require preparation and development of preliminary layouts for review by the Contract Administrator and the City.
3. Delete: Section 11005 clause 2.5.1
4. Revise: Section 11538 clause 2.1.7 to read: The decanter shall be parked above the design top water level during aeration and settling phases, thereby eliminating any possibility of solids carryover during these phases. The weir of the decanter, when in the park position, shall be no less than 250 mm above top water level.