



## 31-2006 ADDENDUM 4

SUPPLY AND DELIVERY OF DECANTERS FOR THE NORTH END WATER POLLUTION CONTROL CENTRE CENTRATE NITROGEN REMOVAL FACILITY

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: March 29, 2006  
BY: Eric Hutchison P.Eng.  
TELEPHONE NO. (204) 477-5381

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.**

---

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, April 4, 2006.

### **PART E – SPECIFICATIONS**

Revise: Section 11538 clause 2.7.2 to read: Pickle all stainless steel surfaces to remove carbon deposits, grease and oil, and to aid the regeneration of a uniform corrosion resistant chromium oxide film. Pickle by means of a full immersion passivation bath. Assemblies too large for full immersion in passivation bath can be Surfox™ cleaned.