



384-2006 ADDENDUM 2

REPLACE ROOF SHINGLES AT SILVER HEIGHTS COMMUNITY CENTRE – 2080 NESS AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 20, 2006
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- | | |
|------------|---|
| Add: E4.27 | Install the specified siding over the existing siding on the centre elevation change. This is to include for the entire wall out to the north corner. Remove the old battens and then securely fasten to the underlying wood siding. Install with appropriate drip and closure flashings. Install Tyvek over the old siding before installing the new. Extend all electrical, lighting and venting. |
| Add: E4.28 | Replace all existing step flashing with new. |