



# 552-2006 ADDENDUM 1

**BROADWAY/EXCHANGE DISTRICT – SIDEWALK IMPROVEMENTS  
PRINCESS STREET – NOTRE DAME AVENUE TO JAMES AVENUE  
KING STREET – NOTRE DAME AVENUE TO WILLIAM AVENUE  
ARTHUR STREET - MCDERMOT AVENUE TO BANNATYNE AVENUE  
BROADWAY – MIEMORIAL BOULEVARD TO MAIN STREET**

ISSUED: September 11, 2006  
BY: Coleen Groening  
TELEPHONE NO. (204) 986-2491

## **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20060821

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

## **PART A – BID SUBMISSION**

Replace: 552-2006 Bid Submission with 552-2006 Addendum 1- Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1): Numerous changes
- Form G2(R1) Revised expiry date on Page 2 of 2

## **PART B – BIDDING PROCEDURES**

- Revise: B2.1 The Submission Deadline is 12:00 Noon Winnipeg time, September 14, 2006.
- Add: B15.4.3 If the lowest evaluated responsive Bid submitted by a responsible and qualified Bidder exceeds the budgetary provision for the Work, the Total Bid Prices of all responsive Bids submitted by responsible and qualified Bidders will be adjusted by progressively deducting the following items shown on Form B: Prices in the order listed until a Total Bid Price within the budgetary provision is achieved.
  - a) Item No. F.19 Micro Irrigation System
  - b) Item No. F.13 Granite Pavers
  - c) Item No. F.20 i) Broadway Tree Grate
- Add: B15.4.4 If the lowest evaluated responsive Bid is submitted by a responsible and qualified Bidder is within the budgetary provision for the Work, no adjustment will be made to the Total Bid Price.

## **PART D – SUPPLEMENTAL CONDITIONS**

- Revise: D20.1(a) to read: Maintenance of trees as specified in E19 Landscape Maintenance.

## **PART E – SPECIFICATIONS**

Revise: E1.2 to read: The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>
C0001-R0	Arthur Street-McDermot Avenue to Bannatyne Avenue Plan and Profile
L01-R1	Cross Walk – Arthur Street at McDermot Plan and Details
L02-R1	King Street Paving West Side-Bannatyne Avenue to William Avenue Plan
L03-R2	Exchange District Paving and Planting Details
L04-R1	Broadway Avenue North Side Plan
L05-R2	Broadway Streetscape Details
L06-R2	Broadway Irrigation Schematic Plan

Add: E10.2.5 Remove and dispose of sand bedding and debris. Dispose of material in accordance with Section 3.4 of CW 1130. Contract Administrator to review and approve removal of sand bedding prior to base regrading.

Revise: E13.5.1 to read: Clay brick pavers as manufactured by Endicott Clay Products Company and supplied by Alsip Industrial Products Ltd., Winnipeg, MB, (204) 667-3330. Pavers shall conform to ASTM C902. Type 1, dimensional tolerance: 1/8", wire cut face, 102 mm x 204 mm x 60mm depth, solid (not cored). Colour: **dark** ironspot.

Revise: E18.6.2 to read: Structural Soil: to E20.

Revise: E18.10.4.2 to read: Refer to E23 for Vertical Mulching procedure.

Revise: E22.1 to read: This Specification shall cover the supply and installation of a micro-irrigation system delivering water to all **new** boulevard tree wells in two reconstructed blocks on Broadway.

## **DRAWINGS**

Replace: Drawing L03-R1 with Drawing L03-R2

Drawing L05-R1 with Drawing L05 R2.

Drawing L06-R1 with Drawing L06 R2.