



## 673-2006 ADDENDUM 4

### A PUBLIC – PRIVATE PARTNERSHIP FOR EAST DISTRICT POLICE STATION DEVELOPMENT AND OPERATION

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: May 2, 2007  
BY: Henry Bakker, Number TEN Architectural Group  
TELEPHONE NO. (204) 942-0981

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph D, Proposal Certification may render your Bid non-responsive.

---

#### **APPENDIX G – SPECIFICATIONS**

Replace: 00 00 10 TABLE OF CONTENTS with attached 00 00 10 (R4), (6 pages).

Delete: Section 26 24 20 ACTIVE HARMONIC FILTER

#### **DRAWINGS**

Revise: Drawing E1.0 as follows:

1. On Details 2/E1.0 and 3/E1.0, revise car plug receptacles to read "IPLC type receptacle as per specification Section 26 27 27".

Revise: Drawing 3.0 as follows:

1. Delete harmonic filter & feeder shown, breaker to remain.