

GENERAL NOTES:

- 1. CONFORM TO NATIONAL BUILDING CODE OF CANADA AND ALL OTHER APPLICABLE CODES.
- 2. EQUIPMENT LOCATIONS SHOWN ARE APPROXIMATE. CONFIRM ACTUAL LOCATIONS IN FIELD.

KEY NOTES:

- 1) INSTALL NEW ELECTRIC UNIT HEATERS AS SHOWN. PROVIDE CONTROL WIRING BETWEEN THERMOSTAT AND UNIT HEATER. WIRING TO RUN IN CONDUIT.
- 2 INSTALL NEW BASEBOARD HEATER BH-1 AS SHOWN.

LEGEND:

ELECTRICAL/CONTROL WIRING


T

THERMOSTAT

UNIT HEATER SCHEDULE						
TAG	DESCRIPTION	CAPACITY (kW)	VOLTAGE	MAKE/MODEL		
UH-1	ELECTRIC UNIT HEATER	10	208/3/60	"CALORITECH"/GE102 C/W ET5-S REMOTE THERMOSTAT AND WALL MOUNTING BRACKET		
UH-2	ELECTRIC UNIT HEATER	7.5	208/3/60	"CALORITECH"/GE072 C/W ET5-S REMOTE THERMOSTAT AND WALL MOUNTING BRACKET		
UH-3	ELECTRIC UNIT HEATER	10	208/3/60	"CALORITECH"/GE102 C/W ET5-S REMOTE THERMOSTAT AND WALL MOUNTING BRACKET		
UH-4	ELECTRIC UNIT HEATER	10	208/3/60	"CALORITECH"/GE102 C/W ET5-S REMOTE THERMOSTAT AND WALL MOUNTING BRACKET		
UH-5	ELECTRIC UNIT HEATER	7.5	208/3/60	"CALORITECH"/GE072 C/W ET5-S REMOTE THERMOSTAT AND WALL MOUNTING BRACKET		
UH-6	ELECTRIC UNIT HEATER	5	208/3/60	"CALORITECH"/GE052 C/W ET5-S REMOTE THERMOSTAT AND WALL MOUNTING BRACKET		

	ELECTF	RIC BA	ASEBOA	RD HEATER SCHEDULE
TAG	DESCRIPTION	CAPACITY (kW)	VOLTAGE	MAKE/MODEL
BH-1	BASEBOARD HEATER	0.3	120/1/60	"OUELLET"/OFM 0302 C/W BUILT IN THERMOSTAT
BH-2	BASEBOARD HEATER	1.5	120/1/60	"OUELLET"/OFM 1502 C/W CONTACTS FOR REMOTE THERMOSTAT
BH-3	BASEBOARD HEATER	1.5	120/1/60	"OUELLET"/OFM 1502 C/W CONTACTS FOR REMOTE THERMOSTAT





THERMOSTAT - EXTERIOR WALL MOUNTING DETAIL

	B.M. ELEV.				KG	CONS	CONSULTING ENGINEERS & PROJECT MANAGERS	
					GROU	WINNIE		,
	E				DESIGNED BY	PSS	CHECKED RBB	1 (
APEGIN Certificate of Authorization					DRAWN BY	VJH	APPROVED BY] 🐧
KGS Group					HOR. SCALE	10 110750	RELEASED FOR CONSTRUCTION	CONS
No. 245 Expiry: April 30, 2007	NO.	ISSUED FOR TENDER REVISIONS	NOV.16/06 DATE	PSS BY	DATE	AS NOTED NOV. 2006	DATE	06





THE CITY OF WINNIPEG Winnipeg *SERVICES DEPARTMENT

> RIVER PATROL BOAT STORAGE BUILDING **HEATING SYSTEM OPTION 2** UNIT HEATERS

SHEET	OF	
3		8
CAD FILE 06-10	DRAWING 07-17M0	

PROJECT NUMBER 2005-081