



248-2007 ADDENDUM No. 1

SUPPLY AND DELIVERY OF CHLORINE RAILCAR EMERGENCY ISOLATION SYSTEM COMPONENTS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: April 5, 2007
BY: Ken Stelmack
TELEPHONE NO. (204) 986-2293

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20060821

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E2.3 to read: Item No. 2 – shall be: three (3) break away couplings, as manufactured by Hiltap, model number HTBA-10-11-F-3114. Coupling shall be 1", dry chlorine, inline breakaway type, with Hastelloy C wetted parts, carbon steel sleeve, and Viton/Teflon seals. Maximum allowable working pressure shall be 300 psig. Breakaway force shall be 240 ft. lb.

Revise: E2.7 to read: Item No. 6 – shall be: three (3) rupture disk holders, as manufactured by Fike. Rupture disk holders shall be ¾" Union type, Assembly BU with ¾" female national pipe thread inlet and outlet, rated at 3000#, fabricated from carbon steel (base and holddown).