



389-2007 ADDENDUM 1

NEWPCC MAIN BUILDING FEEDER CABLE REPLACEMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 10, 2007
BY: Curtis Reimer, P.Eng.
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

Part E – Specifications

Revise: NMS Section 26 05 13 Clause 2.1.2 to read:

- .2 Three (3) Copper circuit conductors, 250MCM for Bank 1 and 350MCM for Bank 2.