


6 GRIT BUILDING PLAN CONT'D



363 DETAIL



Certificate of Authorization
SNC-Lavalin Engineers &
Constructors Inc. (MB)
No. 2365 Expiry: April 30, 2008

NO. DRAWING NOTES


ROUTE UP TO SWITCHGEAR F2-F3 ABOVE.

DENTIFY CABLES AS PER THE SPECIFICATIONS.

INSTALL NEW 300mm CABLE TRAY AS SHOWN.

REMOVE EXISTING TRAY. INSTALL NEW 300mm TRAY AS SHOWN WITH 300mm CLEARANCE ABOVE ALL TRAYS.

500 0 500 1500 2500mm



1	B.M. ELE\		FIELD BOOK #:			SNC • I.AVALIN		ENGINEER'S SEAL
	POS	TED TO LBIS				SNC • LAVALIN Engineers & Constr	Canada RSP UX/	 PRELIMINARY
						DESIGNED C. REIMER BY	CHECKED BY C. ASMUNDSON	NOT TO BE
						DRAWN A. OLIVER	APPROVED C. REIMER	USED FOR CONSTRUCTION
						HOR. SCALE 1:50 VERTICAL 1:50	RELEASED FOR CONSTRUCTION	
	00	ISSUED FOR TENDER		2007/06/22	YOM	DATE 2007/03/08	DATE	
	NO.	REVISIONS		DATE	BY	FILENAME: 1-0101M-A-EC	0011-005-00D.dwg	

ه ا	\ L
Winni	
<u> </u>	MINARY

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

NORTH END WATER POLLUTION CONTROL CENTRE

MAIN BUILDING FEEDER REPLACEMENTS

CABLE ROUTING PLAN

BANK 1 — 5kV FEEDER

CITY DRAWING NUMBER SHEET REV. SIZE 1-0101M-A-E0011 006 00 D