



400-2007 ADDENDUM 1

SUPPLY AND DELIVERY OF LIQUID FERRIC CHLORIDE FOR THE WEWPCC

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: June 15, 2007
BY: Eric Hutchison, P.Eng.
TELEPHONE NO. (204) 477-5381

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: E3.6.1 The City will provide a 65 mm diameter connection to receive the liquid ferric chloride. The City will provide either a four-bolt PVC flange or a Camlock connector at the Contractor choice.
- Add: E3.6.2 The Contractor shall provide trucks equipped with any additional equipment required, including but not limited to:
- (a) chemical hoses suitable to connect to the City's chemical unloading line;
 - (b) straps or other securing devices to fasten the chemical port to prevent blow-out.