



43-2007 ADDENDUM 1

SUPPLY AND DELIVERY OF FIRE HOSES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 12, 2007
BY: Debbie Shkolny
TELEPHONE NO. (204) 986-2249

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20060821

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 43-2007 Bid Submission with 43-2007 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Revise Items No. 1 and 2.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, February 16, 2007

PART E – SPECIFICATIONS

Revise: E2.2 to read: 1 ½ I.D. 500 PSI. PRESSURE TEST – BURST 750 PSI. 50 FT. COILS **10 INCH TO 12 INCH ROLL, UNCOUPLED WEIGHT OF COILED HOSE BETWEEN 6 LBS. TO 8 LBS.**

Revise: E2.3 to read: 2 ½ I.D. 500 PSI. PRESSURE TEST – BURST 750 PSI. 50 FT. COILS **12 INCH TO 15 INCH ROLL, UNCOUPLED WEIGHT OF COILED HOSE BETWEEN 12 LBS. TO 14 LBS.**

Revise E2.4 (a) to read: | High performance jacket cover, 100% polyester treated to increase abrasion resistance with two (2) year warranty for wear.

Revise E2.4 (b) to read: Inner tube lining compound must be free of risk from rotting or mildew, no maintenance required.