


LUMINAIRE SCHEDULE								
TYPE	MANUFACTURER	CAT. No.	LAMP	VOLTAGE	REMARKS			
1	BRYANT	5228	100W INCAND.	120V	MEDIUM BASE PORCELAIN BODY KEYLESS SUITABLE FOR MOUNTING ON A 100 (4:") ROUND DEVICE BOX, C/W WIRE LAMP GUARD AND GROUNDING KIT			
2	LITHONIA	TWR1C 100S 120 LPI CSA	100W HPS	120V	OUTDOOR WALLPACK UNIT, BRONZE FINISH 120V FULL CUTOFF			
3	LITHONIA	BWX-232-120-GEB101S	2-32W T8	120V	SURFACE MOUNT FLUORESCENT C/W PRISMATIC LENS			
4	AIMLITE	CXST6-36-1-W-2MD -WHT-ATD	2 MR16 8WQ	6V / 120V	WALL MTD. EXIT SIGN C/W 2 8W EMERG. LTG. LAMPS WITH INTEGRAL BATTERY UNIT			
5	LITHONIA	C-232-120-GEB101S	4-32W T8	120V	8' SURFACE MOUNT FLUORESCENT STRIP LIGHT C/W ENAMEL WIRE GUARD AND ASYMMETRICAL REFLECTOR			
6	LITHONIA	RIU-232-120-GEB101S-HC	2-32W T8	120V	CHAIN SUSPENDED INDUSTRIAL FLUORESCENT C/W UPLIGHT. MTD AT 3000 ABOVE FIN. FLOOR			


NOTES :

- 1. ALL LUMINAIRES SHALL COME COMPLETE WITH LAMPS AND MANITOBA HYDRO POWER SMART APPROVED BALLASTS.
- 2. CHAIN SUPPORTS FOR TYPE 6 LUMINAIRE SHALL NOT PENETRATE ROOF STRUCTURE. FASTEN CHAINS TO METAL CHANNEL FASTENED TO CEILING JOISTS.
- 3. REPLACE DUPLEX RECEPTACLE WITH COVER PLATE AND FLEX CONDUIT CONNECTOR FOR CONNECTION TO MODULAR FURNITURE WIRING
- 4. CIRCUIT NEW POWER POLES FROM CIRCUIT BREAKERS LEFT AS SPARE FROM RECEPTACLE DEMOLITION. CONFIRM LOCATION OF POLES WITH FURNITURE SUPPLIER.
- 5. REPLACE EXISTING LIGHTING SWITCHES WITH NEW EQUIPMENT, RELOCATE AND RECONNECT TO EXISTING LIGHTING CIRCUITS AS INDICATED.
- 6. CONNECT HEAT DETECTOR TO EXISTING F.A. SYSTEM. PROVIDE F. A. VERIFICATION TEST REPORT FOR ALL NEW DEVICES.

CEALC					
NO.	REVISION/DESCRIPTION	BY	DATE		
Α	ISSUED FOR CLIENT REVIEW	QL	07/08/17		
В	ISSUED FOR 100% REVIEW	SCK	07/09/12		
С	ISSUED FOR FINAL REVIEW	SCK	07/10/1		
D	ISSUED FOR TENDER	SCK	07/11/0		
Ł	ISSUED FOR ADDENDUM No.1	2CK	0//11/14		




DRAWN BY SCK CHECKED BY DATE 2007.05.09 USER APPROVAL 2007.05.09 USER APPROVAL



300 - 65 GARRY ST. R3C 4K4 PROJECT

CONSTRUCTION OF OFFICE/GARAGE **RENOVATIONS & STORAGE BUILDING** AT 1539 WAVERLEY STREET

1539 Waverley Street, Winnipeg, MB. SHEET TITLE



DRN CHK DES ENG IDR

**UMA REVIEW** 

**ELECTRICAL** OFFICE MAIN AND SECOND FLOOR NEW CONSTRUCTION

SHEET NO. OFF-E2.1 0265-395-02

PROJECT NO.

DRAWING SHEET SIZE: A1 (841mm x 594mm) PLOT 1:1