

Part 1 General

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA B111-[1974(R1998)], Wire Nails, Spikes and Staples.
 - .2 CAN/CSA-G164-[M92(R1998)], Hot Dip Galvanizing of Irregularly Shaped Articles.
 - .3 CSA O121-[M1978(R1998)], Douglas Fir Plywood.
 - .4 CAN/CSA-O141-[91(R1999)], Softwood Lumber.
 - .5 CSA O151-[M1978(R1998)], Canadian Softwood Plywood.
 - .6 CAN/CSA-O325.0-[92(R1998)], Construction Sheathing.
- .2 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2000.

1.2 QUALITY ASSURANCE

- .1 Lumber identification: by grade stamp of an agency certified by Canadian Lumber Standards Accreditation Board.
- .2 Plywood identification: by grade mark in accordance with applicable CSA standards.
- .3 Plywood, OSB and wood based composite panel construction sheathing identification: by grademark in accordance with applicable CSA standards.

Part 2 Products

2.1 LUMBER MATERIAL

- .1 Lumber: unless specified otherwise, softwood, S4S, moisture content 19% or less in accordance with following standards:
 - .1 CAN/CSA-O141.
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
- .2 Furring, blocking, nailing strips, grounds, rough bucks, cants, curbs, fascia backing and sleepers:
 - .1 Board sizes: "Standard" or better grade.
 - .2 Dimension sizes: "Standard" light framing or better grade.
 - .3 Post and timbers sizes: "Standard" or better grade.

2.2 PANEL MATERIALS

- .1 Douglas fir plywood (DFP): to CSA O121, standard construction.
- .2 Canadian softwood plywood (CSP): to CSA O151, standard construction.

□

- .3 Plywood, OSB and wood based composite panels: to CAN/CSA-O325.

2.3 ACCESSORIES

- .1 Nails, spikes and staples: to CSA B111.
- .2 Bolts: [12.5] mm diameter unless indicated otherwise, complete with nuts and washers.
- .3 Proprietary fasteners: toggle bolts, expansion shields and lag bolts, screws and lead or inorganic fibre plugs, [explosive actuated fastening devices], recommended for purpose by manufacturer.

2.4 FINISHES

- .1 Galvanizing: to CAN/CSA-G164, use galvanized fasteners for exterior work and Interior highly humid areas.

2.5 WOOD PRESERVATIVE

- .1 Surface-applied wood preservative: Copper naphthenate or 5% pentachlorophenol solution, water repellent preservative.
- .2 Pentachlorophenol use is restricted to building components that are in ground contact and subject to decay or insect attack only. Where used, pentachlorophenol-treated wood must be covered with two coats of an appropriate sealer.
- .3 Structures built with wood treated with pentachlorophenol and inorganic arsenicals must not be used for storing food nor should the wood come in contact with drinking water.

Part 3 Execution

3.1 INSTALLATION

- .1 Comply with requirements of NBC, supplemented by the following paragraphs.
- .2 Install furring and blocking as required to space-out and support casework, cabinets, wall and ceiling finishes, facings, fascia, soffit, siding and other work as required.
- .3 Align and plumb faces of furring and blocking to tolerance of 1:600.
- .4 Install rough bucks, nailers and linings to rough openings as required to provide backing for frames and other work.
- .5 Install fascia backing, nailers, curbs and other wood supports as required and secure using [galvanized] [steel] fasteners.
- .6 Install wood backing, dressed, tapered and recessed slightly below top surface of roof insulation for roof hopper.
- .7 Install sleepers as indicated.

- .8 Use caution when working with particle board. Use dust collectors and high quality respirator masks.

3.2 Erection

- .1 Frame, anchor, fasten, tie and brace members to provide necessary strength and rigidity.
- .2 Countersink bolts where necessary to provide clearance for other work.

3.3 Schedules

- .1 Provide electrical equipment backboards for mounting electrical equipment as indicated. Use 19 mm thick plywood on 19 x 38 mm furring around spacing, perimeter and at maximum 300 mm intermediate

3.4 ERECTION

- .1 Frame, anchor, fasten, tie and brace members to provide necessary strength and rigidity.
- .2 Countersink bolts where necessary to provide clearance for other work.

3.5 SCHEDULES

- .1 Provide electrical equipment backboards for mounting electrical equipment as indicated. Use [19] mm thick plywood on 19 x 38 mm furring around spacing, perimeter and at maximum 300 mm intermediate

END OF SECTION