
UPS-1 INSTRUCTIONS

Startup Procedure

- 1. Turn the Manual Bypass Switch to the Bypass position.
- 2. Ensure that the "Normal Power" breaker is closed and supplying power.
- 3. Close the "UPS" supply breaker to provide power to the UPS.
- 4. Turn on the UPS battery circuit breaker, located at the rear of the UPS.
- 5. Using the ↑ button, select the *Control* menu and press the → button.
- 6. Press ← to select the *Go to Bypass Mode* option.
- 7. Wait for the -○→ indicator to illuminate on the UPS.
- 8. Turn the Manual Bypass Switch to the UPS position.
- 9. Press the ← button to select the *Go To Normal Mode* option.
- 10. Press the ESC button until the Eaton Powerware logo appears.

Shutdown Procedure

- 1. Using the \uparrow button, select the *Control* menu and press the \rightarrow button.
- 2. Press ← to select the Go to Bypass Mode option.
- 3. Wait for the -⊙→ indicator to illuminate on the UPS.
- 4. Turn the Manual Bypass Switch from the UPS position to the Bypass position.
- 5. Press the \uparrow button on the front panel display and then press the \rightarrow button to select the *TURN UPS ON/OFF* menu.
- 6. Press the ↓ button to select the *TURN UPS OFF* option; press the ← button.
- 7. Confirm the selection. Press and hold the ← button for three seconds, until the UPS stops beeping.
- 8. Turn off the UPS battery circuit breaker, located at the rear of the UPS.
- 9. Open the "UPS" source breaker.



		B.M. ELE\		FIELD BOOK #:			(SNC-LAVALIN INC. 148 Nature Park Way	ENGINEER'S SEAL	©	THE CITY OF	\A/ININI	IDEC
	POSTED TO LBIS		TED TO LBIS					Winnipeg, MB, Canada R3P 0X7 204-786-8080	 PRELIMINARY	Winnipeg	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT		
							DESIGNED C. REIMER BY	CHECKED C. REIMER	1101 10 52		SHOAL LAKE INTAKE		
	EAPEGIN Certificate of Authorization						DRAWN E. BOHNCKE	APPROVED C. REIMER	USED FOR	UPS UPGRADES OPERATING INSTRUCTIONS			
							HOR. SCALE NTS VERTICAL NTS DATE 2007/10/11	RELEASED FOR CONSTRUCTION	CONSTRUCTION	UPS-1			
	SNC-Lavalin Inc. (MB) No. 4489 Expiry: April 30, 2008	0	ISSUED FOR TENDER		2008/01/08	AEO		DATE		CITY DRAWING NUMBER		1 1	REV. SIZE
No		NO.	REVISIONS		DATE	BY	FILENAME: 1-0600M-E00	02-001-00.dwg		1-00001	<u>И-Е0002</u>	001	0 A1

4ST SAVE: 2008/01/09 - 10:24am ATH: M:\113063\4ENG\47ELE\DD - General DWG\1-0600M-