
UPS-1 INSTRUCTIONS

Startup Procedure

- 1. Turn the Manual Bypass Switch to the Bypass position.
- 2. Ensure that the "Normal Power" breaker is closed and supplying power.
- 3. Close the "UPS" supply breaker to provide power to the UPS.
- 4. Turn on the UPS battery circuit breaker, located at the rear of the UPS.
- 5. Using the \uparrow button, select the *Control* menu and press the \rightarrow button.
- 6. Press ← to select the *Go to Bypass Mode* option.
- 7. Wait for the -O+ indicator to illuminate on the UPS.
- 8. Turn the Manual Bypass Switch to the UPS position.
- 9. Press the ← button to select the *Go To Normal Mode* option.
- 10. Press the ESC button until the Eaton Powerware logo appears.

Shutdown Procedure

- 1. Using the \uparrow button, select the *Control* menu and press the \rightarrow button.
- 2. Press ← to select the *Go to Bypass Mode* option.
- 3. Wait for the -⊙→ indicator to illuminate on the UPS.
- 4. Turn the Manual Bypass Switch from the UPS position to the Bypass position.
- 5. Press the ↑ button on the front panel display and then press the → button to select the *TURN UPS ON/OFF* menu.
- 6. Press the \downarrow button to select the *TURN UPS OFF* option; press the \leftarrow button.
- 7. Confirm the selection. Press and hold the ← button for three seconds, until the UPS stops beeping.
- 8. Turn off the UPS battery circuit breaker, located at the rear of the UPS.
- 9. Open the "UPS" source breaker.



		B.M. ELEV.		FIELD BOOK #:		•))	SNC-LAVALIN INC. 148 Nature Park Way	ENGINEER'S SEAL	THE CITY OF WINNIPEG					
		P09	STED TO LBIS				SNC·LAVALIN	Winnipeg, MB, Canada R3P 0X7 204-786-8080	PRELIMINARY NOT TO BE	Winnipeg Water and Waste Department				
							DESIGNED C. REIMER	CHECKED C. REIMER		MCPHILLIPS PUMPING STATION				
	Certificate of Authorization SNC-Lavalin Inc. (MB)						DRAWN E. BOHNCKE	APPROVED C. REIMER	USED FOR	UPS UPGRADES OPERATING INSTRUCTIONS UPS-1				
							HOR. SCALE NTS VERTICAL NTS DATE 2007/10/11	RELEASED FOR CONSTRUCTION	CONSTRUCTION					
			ICCUED FOR TENDER		2008/01/08	AF0		DATE		CITY DRAWING NUMBER	?	SHEET	REV.	SIZE
	No. 4489 Expiry: April 30, 2008	NO.	ISSUED FOR TENDER REVISIONS		DATE		FILENAME: 1-0640M-E00			1-06401	M−E0012	001	0	A1

LAST SAVE: 2008/01/09 - 10:53am PATH: M:\113063\4FNG\47FLF\DD - General DWG\1-0640M-