
UPS-1 INSTRUCTIONS

Startup Procedure

- 1. Turn the Manual Bypass Switch to the Bypass position.
- 2. Ensure that the "Normal Power" breaker is closed and supplying power.
- 3. Close the "UPS" supply breaker to provide power to the UPS.
- 4. Turn on the UPS battery circuit breaker, located at the rear of the UPS.
- 5. Using the ↑ button, select the *Control* menu and press the → button.
- 6. Press ← to select the *Go to Bypass Mode* option.
- 7. Wait for the -○→ indicator to illuminate on the UPS.
- 8. Turn the Manual Bypass Switch to the UPS position.
- 9. Press the ← button to select the *Go To Normal Mode* option.
- 10. Press the ESC button until the Eaton Powerware logo appears.

Shutdown Procedure

- 1. Using the \uparrow button, select the *Control* menu and press the \rightarrow button.
- 2. Press ← to select the *Go to Bypass Mode* option.
- 3. Wait for the -⊙→ indicator to illuminate on the UPS.
- 4. Turn the Manual Bypass Switch from the UPS position to the Bypass position.
- 5. Press the ↑ button on the front panel display and then press the → button to select the *TURN UPS ON/OFF* menu.
- 6. Press the ↓ button to select the *TURN UPS OFF* option; press the ← button.
- 7. Confirm the selection. Press and hold the ← button for three seconds, until the UPS stops beeping.
- 8. Turn off the UPS battery circuit breaker, located at the rear of the UPS.
- 9. Open the "UPS" source breaker.



	B.M. FIELD BOOK #: ELEV.				(SNC-LAVALIN INC.	ENGINEER'S SEAL	THE CITY OF WINNIPEG
	POSTED TO LBIS				SNC·LAVALIN	Winnipeg, MB, Canada R3P 0X7 204-786-8080	PRELIMINARY	Winnipeg water and waste department
APEGIN					DESIGNED C. REIMER	CHECKED C. REIMER	NOT TO BE USED FOR CONSTRUCTION	HURST PUMPING STATION UPS UPGRADES OPERATING INSTRUCTIONS UPS-1
					DRAWN E. BOHNCKE	APPROVED C. REIMER		
Certificate of Authorization					HOR. SCALE NTS VERTICAL NTS	RELEASED FOR CONSTRUCTION		
SNC-Lavalin Inc. (MB)	00	ISSUED FOR TENDER	2008/01/08	AEO		DATE		CITY DRAWING NUMBER SHEET REV. SIZE
No. 4489 Expiry: April 30, 2008	NO.	REVISIONS	DATE	BY	FILENAME: 1-0650M-E0012-001-00.dwg			1-0650M-E0012 001 00 A1

ST SAVE: 2008/01/09 - 10:54am TH: M:\113063\4FNG\47FL\DD - General DWG\1-0650N