

97-2007 ADDENDUM 5

WINNIPEG WATER TREATMENT PROGRAM – CONSTRUCTION OF ROADS AND LANDSCAPING

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: December 18, 2007 BY: Lawrence Recksiedler, C.E.T. TELEPHONE NO. (204) 986-4246

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A - BID SUBMISSION

Replace: 97-2007_Addendum_4-Bid_Submission with 97-2007_Addendum_5-Bid_Submission. Form B(R2) has been

replaced by Form B(R3). Item A.5 "Fill Material" has been deleted.

PART E - SPECIFICATIONS

Clarification: With reference to Drawing 1-0601Y-A-C0263-001-01D, the base of the CHEMICAL CONTAINMENT

manhole is at Elev 231.61, and the work includes the 3.0m sump, 2700mm to 1200mm reducer, 1200mm

to 750mm reducer and frame and cover.