



360-2008 ADDENDUM 1

SUPPLY AND DELIVERY OF WATER, SEWER PIPE AND ACCESSORIES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 25, 2008
BY: Ken M. Stelmack, C.P.P., C.P.M., C.I.M.
TELEPHONE NO. (204) 986-2293

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 360-2008 Bid Submission with 360-2008 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Replace: Form B(R1):

PART B – BIDDING PROCEDURES

Revise B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, July 7, 2008.

PART E – SPECIFICATIONS

Revise: E2 to read:

E2 GOODS

- E2.1 The Contractor shall supply and deliver water, sewer pipe and accessories in accordance with the requirements hereinafter specified.
- E2.2 SECTION A shall be Water Pipe:
- (a) Item No's. 1, 4, 6, 8, and 10 shall be AWWA C900 polyvinyl chloride (PVC) DR 18 Pressure Water Pipe (150mm – 300mm) CIOD in accordance with File Code 4.1.1.10, Standard Construction Spec Reference CW 2110-R6.
 - (b) Item No's. 2, 3, 5, 7, and 9 shall be AWWA C900 "cut and bevelled at both ends" shall be polyvinyl chloride (PVC) water pipe approved for underground use in accordance with the most recent revision of The City of Winnipeg Standard No. AT- 4.1.1.10. Products.
 - (c) Items No's. 12, 14, 16 and 18 shall be AWWA C905 Large Diameter polyvinyl chloride (PVC) DR 18 Pressure Water Pipe (350mm – 500mm) in accordance with File Code 4.1.1.11, Standard Construction Spec Reference CW 2110-R6.
 - (d) Items No's. 11, 13, 15, and 17 shall be AWWA C900 "cut and bevelled at both ends" shall be polyvinyl chloride (PVC) water pipe approved for underground use in accordance with the most recent revision of The City of Winnipeg Standard No. AT- 4.1.1.10. Products.

E2.3 SECTION B shall be Sewer Pipe:

- (a) Item No's. 19 - 23 shall be Main Line (100mm – 200mm) in accordance with File Code 4.2.1.10, Standard Construction Spec Reference CW 2130-R6.
- (b) Item No's. 24 - 29 shall be Main Line SDR 35 polyvinyl chloride (PVC) Gravity Sewer Pipe (250mm – 450mm) in accordance with File Code 4.2.1.10, Standard Construction Spec Reference CW 2130-R6.

E2.4 SECTION C shall be Sewer Elbows:

- (a) Item No's. 30 - 40 shall be Main Line Injection Moulded SDR 35 polyvinyl chloride (PVC) Sewer fittings (150mm – 400mm) in accordance with File Code 4.2.1.60, Standard Construction Spec Reference CW 2130-R6.

E2.5 SECTION D shall be Sewer Pipe Bushings:

- (a) Item No. 41 shall be Main Line Injection Moulded SDR 35 polyvinyl chloride (PVC) Sewer pipe bushings (150mm – 300mm) in accordance with File Code 4.2.1.60, Standard Construction Spec Reference CW 2130-R6.

E2.6 SECTION E shall be Sewer Tees:

- (a) Item No's. 42 - 48 shall be Main Line Injection Moulded SDR 35 polyvinyl chloride (PVC) Sewer pipe tees (200mm – 300mm) in accordance with File Code 4.2.1.60, Standard Construction Spec Reference CW 2130-R6.