



582-2008 ADDENDUM 1

KIRKBRIDGE PARK – PHASE 3 SITE DEVELOPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 25, 2008
BY: Cynthia Cohlmeier
TELEPHONE NO. (204) 943-1394

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E12.9.7(a) to read: Obtain approval of planting before mulching material is applied. Loosen soil in planting beds and pits and remove debris and weeds. **Spread mulch to minimum thickness of 100 mm (4") depth of wood chip mulch.** Mulch material susceptible to blowing must be moistened and mixed with topsoil before applying. When mulching is placed in fall, place immediately after planting. When mulch is placed in spring, wait until soil has warmed.