



# 582-2008 ADDENDUM 3

## KIRKBRIDGE PARK – PHASE 3 SITE DEVELOPMENT

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: July 31, 2008  
BY: Cynthia Cohlmeier  
TELEPHONE NO. (204) 943-1394

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.**

---

### **PART A – BID SUBMISSION**

Replace: 582-2008 Bid Submission with 582-2008 Addendum 3 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Item no. 18 should read: supply, installation, wiring and connection of pole lights / E9 / lump / 6

### **PART E – SPECIFICATIONS**

Revise: E9.4.1 to read: Light Fixture: SDL #VP80-LR2-100S-120/240-A11-PC8G c/w 100W HPS lamp. Fixture shall be powder coated. For information see: <http://www.sdllighting.com/a-12evp806g.html>

Revise: E9.4.2 to read: Light Pole: 6.7m (22') long, 127mm (5") diameter round steel direct burial pole c/w tenon sized to accommodate the fixture. Black colour, powder coated, with rust inhibitor.

Revise: E9.5.2 to read: Install poles under the electrical contract. Direct burial poles are to be installed with 4.57m (15') above ground and 2.13m (17') below ground. Contract Administrator must be present to verify depth of existing wiring prior to posts being pushed.

Add: E9.4.3: Service box details are shown on Drawing L-6.

Add: E9.4.6: As Built Drawings: The Electrical Contractor shall provide As-Built drawings to the Contract Administrator upon completion of the project. All underground services shall be indicated and dimensioned.

### **DRAWINGS**

Replace: 582-2008 \_Drawing\_L-1 with 582-2008 \_Addendum\_3 -Drawing L1-R1

582-2008 \_Drawing\_L-5 with 582-2008 \_Addendum\_3 -Drawing L5-R1

Add: 582-2008 \_Drawing\_ L-6-R0