



584-2008 ADDENDUM 2

REPLACEMENT OF AIR CONDITIONERS (AF30)

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 12, 2008
BY: Ken M. Stelmack, C.P.P., C.P.M., C.I.M.
TELEPHONE NO. (204) 986-2293

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.12

The replacement unit shall meet the functionality of the above unit or exceed and come complete with an economizer low leak dampers and barometric relief.