



## 589-2008 ADDENDUM 1

### PANET ROAD CROSSING OF DUGALD ROAD DRAIN REPLACEMENT

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: August 29, 2008  
BY: James Kennedy, P.Eng.  
TELEPHONE NO. (204) 284-0580

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

---

#### **TABLE OF CONTENTS**

Add: Form B:Prices

#### **PART E – SPECIFICATIONS**

Revise: E10.3.1, E10.3.2, and E10.3.3 on page 3 of 16 to read E8.3.1, E8.3.2, and E8.3.3 respectively.

Add: E9.4.6 to read: The City intends to shut down the feedermain for the duration that it is exposed. The Contractor shall give the City at least seven (7) days notice of their intention to expose the pipe. In order to minimize the duration of the shutdown the Contractor shall complete backfill construction within a minimum envelope of 0.600 metres of the feedermain within two (2) Calendar Days of the initial shutdown.

#### **DRAWINGS**

Replace: 589-2008 \_Drawing\_ 03-R0 with 589-2008 \_Drawing\_ 03-R1.